



XCE 1224 COVER

- COVER DRILLING ALLOWABLE IN XCE ONLY
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1/4"
 2. MINIMUM SPACING BETWEEN 1/4" MTSX OPERATOR CENTERS IS 3" FOR THIS ENCLOSURE.
 3. MINIMUM SPACING BETWEEN 1/4" MTSX OPERATOR CENTERS IS 3" FOR THIS ENCLOSURE.
 4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
 5. DIMENSION FROM CENTER LINE AND BACK OF MTC. LUG FOR CONDUIT.
 6. FOR MTC. ENCLOSURE USE 1/2" BOLT.