REV	REVISION	BY	ECN	DATE



XCE 1830 N4 COVER

NOTES:

COVER DRILLING ALLOWABLE IN XCE ONLY

1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/16.
2. MINIMUM SPACING BETWEEN 3/4-14 NPSM OPERATOR CENTERS IS 3 1/2 FOR THIS ENCLOSURE.
3. MAXIMUM NUMBER OF OPERATORS IS 32.
4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
5. DIMENSION FROM CENTER LINE AND BACK OF MTG. LUG FOR CONDUIT.
6. FOR MTG. ENCLOSURE USE 1/4 BOLT.

DO NOT SCALE DRAWING

ADALET
A SCOTT FETZER COMPANY
Enclosure Systems Cable Accessories

TITLE: MODIFIED XCEQ 183008 N4 ENCLOSURE FOR

DRAWN BY	DDH	DATE	11-16-01
ENG APPROVAL		PLOT SCALE	1=4
MFG APPROVAL		DWG SIZE	D
DWG NO		SHT	1OF1
		REV	

MATERIAL
FINISH: TUMBLAST
CAT NO: XCEQ 183008 N4