



XCE 2436 COVER

- COVER DRILLING ALLOWABLE IN XCE ONLY
- NOTES:
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8".
 2. MINIMUM SPACING BETWEEN 3/4"-1 1/4" NPSM OPERATOR CENTERS IS 3/4" FOR THIS ENCLOSURE.
 3. MAXIMUM NUMBER OF OPERATORS IS 54.
 4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
 5. DIMENSION FROM CENTER LINE AND BACK OF MTG. LUG FOR CONDUIT.
 6. FOR MTG. ENCLOSURE USE 3/8" BOLT.

MODIFIED XCE 243610 ENCLOSURE FOR

SEE NOTES
TUMBLAST
XCE 243610

DDH 4-15-02
1=5,5
D
10F1