REV	REVISION	BY	ECN	DATE













XCE 3236 COVER



COVER DRILLING ALLOWABLE IN XCE ONLY

NOTES:

1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/16.
2. MINIMUM SPACING BETWEEN ¾–14 NPSM OPERATOR CENTERS IS 3½ FOR THIS ENCLOSURE.
3. MAXIMUM NUMBER OF OPERATORS IS 72.
4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
5. DIMENSION FROM CENTER LINE AND BACK OF MTG. LUG FOR CONDUIT.
6. FOR MTG. ENCLOSURE USE ⅜ BOLT.

DO NOT SCALE DRAWING

ADALET
A SCOTT FETZER COMPANY
Enclosure Systems Cable Accessories

TITLE: MODIFIED XCE 323612 ENCLOSURE FOR

DRAWN BY	DDH	DATE	11-15-01
ENG APPROVAL		PLOT SCALE	1=5.5
MFG APPROVAL		DWG SIZE	D
DWG NO		SHT	1OF1
MATERIAL		REV	
FINISH	TUMBLAST		
CAT NO	XCE 323612		