



XCE 1836 COVER

- NOTES:
- COVER DRILLING ALLOWABLE IN XCE ONLY
 - 1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/2".
 - 2. MINIMUM SPACING BETWEEN 3/4"-14" NPSM OPERATOR CENTERS IS 3 1/2" FOR THIS ENCLOSURE.
 - 3. MAXIMUM NUMBER OF OPERATORS IS 36.
 - 4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
 - 5. DIMENSION FROM CENTER LINE AND BACK OF MTG. LUG FOR CONDUIT.
 - 6. FOR MTG. ENCLOSURE USE 3/8" BOLT.

DO NOT SCALE DRAWING	ADALET A SCOTT FITZGER COMPANY Electrical Systems Cable Accessories	TITLE	
UNLESS OTHERWISE SPECIFIED		MODIFIED XCE/XIF 183608 ENCLOSURE FOR	
CONFORM TO ALL APPLICABLE CODES	DRAWN BY: DDH DATE: 11-16-01 CHECKED BY: TUMBLAST DATE: 11-16-01 APPROVED BY: TUMBLAST DATE: 11-16-01	DATE: 11-16-01 DRAWN BY: DDH DATE: 11-16-01 CHECKED BY: TUMBLAST DATE: 11-16-01 APPROVED BY: TUMBLAST DATE: 11-16-01	DRAWN BY: DDH DATE: 11-16-01 CHECKED BY: TUMBLAST DATE: 11-16-01 APPROVED BY: TUMBLAST DATE: 11-16-01
ALL DIMENSIONS IN INCHES UNLESS OTHERWISE SPECIFIED	PART NO: XCE/XIF 183608 REV: 1	DRAWN BY: DDH DATE: 11-16-01 CHECKED BY: TUMBLAST DATE: 11-16-01 APPROVED BY: TUMBLAST DATE: 11-16-01	DRAWN BY: DDH DATE: 11-16-01 CHECKED BY: TUMBLAST DATE: 11-16-01 APPROVED BY: TUMBLAST DATE: 11-16-01