



XCE 1414 COVER

NOTES:

- COVER DRILLING ALLOWABLE IN XCE ONLY
1. MINIMUM SPACING FROM CENTER OF OPERATOR TO NEAREST FLAT IS 1 1/8.
  2. MINIMUM SPACING BETWEEN 3/4-14 NPSM OPERATOR CENTERS IS 3 FOR THIS ENCLOSURE.
  3. MAXIMUM NUMBER OF OPERATORS IS 16.
  4. DIMENSION FROM CENTER LINES OF COVER FOR OPERATORS.
  5. DIMENSION FROM CENTER LINE AND BACK OF MTG. LUG FOR CONDUIT.
  6. FOR MTG. ENCLOSURE USE 1/2 BOLT.

<p>DO NOT SCALE DRAWING</p> <p>UNLESS OTHERWISE SPECIFIED DIMENSIONS ARE IN INCHES.</p> <p>CAST TOLERANCES ON DIMENSIONS NOT OTHERWISE SPECIFIED: 1/2" = 1/16" STOCK</p> <p>FILLET OR CORNER RADII 1/8"</p> <p>SHAFT 1/2"</p> <p>FRAC ± 1/16"</p> <p>ANGLES ± 1°</p> <p>MACHINE TOLERANCES ON DIMENSIONS NOT OTHERWISE SPECIFIED: 1/2" = 1/32"</p> <p>Ø ± .015"</p> <p>JOK ± .010"</p> <p>EDGE BREAK .005" - .015" R. or 45°</p> <p>ANGLES ± 0°-30°</p> <p>GAGING FOR THERMAD HOLE</p> <p>UNLESS OTHERWISE SPECIFIED: NPSM E-24-1.0</p>	<p><b>ADALET</b></p> <p>A SCOTT FETZER COMPANY</p> <p>Enclosures • Systems • Cable Accessories</p> <p>NOTICE TO PERSONS RECEIVING THIS DRAWING: ADALET-PLM CLAIMS PROPRIETARY RIGHTS IN THE MATERIAL RECLOSED HEREON. THIS DRAWING IS ISSUED IN CONFIDENCE FOR ENGINEERING INFORMATION ONLY AND MAY NOT BE REPRODUCED OR USED TO MANUFACTURE ANYTHING SHOWN HEREON WITHOUT WRITTEN PERMISSION FROM ADALET-PLM TO THE USER.</p> <p>MATERIAL: TUMBLAST</p> <p>FINISH: TUMBLAST</p> <p>CAT NO: XCE/XJF 141406</p>	<p>TITLE: MODIFIED XCE/XJF 141406 ENCLOSURE FOR</p> <p>DRAWN BY: DDH</p> <p>DATE: 11-13-01</p> <p>ENG APPROVAL: [Signature]</p> <p>PLDW SCALE: 1=3</p> <p>MFG APPROVAL: [Signature]</p> <p>DWG SIZE: D</p> <p>DWG NO: [Blank]</p> <p>SET: 10F1</p> <p>REV: [Blank]</p>
---	--	--