


CLASS I, DIV 2 • CLASS I, ZONE 2

Factory Sealed Panelboards Power Panel Main Lug Only

Panelboards



CERTIFICATIONS

Class I, Div. 2, Groups B, C, D
 Class II, Div. 2, Groups F & G
 Class III
 Class I, Zone 2, IIB+H₂
 Type 4X & 13
 IP66



CLASS I, DIV 2 • CLASS I, ZONE 2

DIMENSIONAL OUTLINE

Catalog #	A	B	C	D	E	F	G
X2PB3-4_	49.80	28.88	22.88	14.46	18.38	21.75	0.69
X2PB3-6_	55.80	34.88	22.88	14.35	23.00	21.75	0.69
X2PB3-8_	55.80	34.88	22.88	14.35	23.00	21.75	0.69
X2PB3-10_	61.80	40.88	22.88	14.54	29.00	21.75	0.69

POWER PANELS

Catalog #	Eaton Cutler Hammer Pow-R-Line C Panelboards			
	# 3-Pole Branch Brkrs	Electrical Rating	Buss Amp	Chassis Type
X2PB3-434-L2_	4	3Ø-3W 480V	225	PRL3A
X2PB3-634-L2_	6	3Ø-3W 480V	225	PRL3A
X2PB3-834-L2_	8	3Ø-3W 480V	225	PRL3A
X2PB3-1034-L2_	10	3Ø-3W 480V	225	PRL3A
X2PB3-444-L2_	4	3Ø-3W 480V	225	PRL3A
X2PB3-644-L2_	6	3Ø-4W 480V	225	PRL3A
X2PB3-844-L2_	8	3Ø-4W 480V	225	PRL3A
X2PB3-1044-L2_	10	3Ø-4W 480V	225	PRL3A
X2PB3-436-L2_	4	3Ø-3W 600V	225	PRL3A
X2PB3-636-L2_	6	3Ø-3W 600V	225	PRL3A
X2PB3-836-L2_	8	3Ø-3W 600V	225	PRL3A
X2PB3-1036-L2_	10	3Ø-3W 600V	225	PRL3A
X2PB3-446-L2_	4	3Ø-4W 600V	225	PRL3A
X2PB3-646-L2_	6	3Ø-4W 600V	225	PRL3A
X2PB3-846-L2_	8	3Ø-4W 600V	225	PRL3A
X2PB3-1046-L2_	10	3Ø-4W 600V	225	PRL3A

BRANCH BREAKERS

Volts	Type
480	EHD
600	FDB


NOTES:

1. For Bottom Fed Model add suffix -B
2. For Top Fed Model add suffix -T
3. 10kA Maximum Interrupting Capacity (Sym.)

CLASS I, DIV 2 • CLASS I, ZONE 2

Factory Sealed Panelboards Power Panel Main Lug Only

WIRING DIAGRAM




Panelboards

CLASS I, DIV 2 • CLASS I, ZONE 2

Factory Sealed Panelboards Power Panel Main Lug Only

WIRING DIAGRAM



3 PHASE - 4 WIRE

Panelboards